SI.No.	Reference Clause No.	Page No	Query from bidder	TCED Reply
1	Bid Security/ Bid Securing Declaration	Clause 18 Part-I	Earnest money deposit (EMD)/ Bid security deposit will be submit through online or Bank guarantee please confirm.	Both are permissible.
2	Performance Security	ITB 44.1	Request to consider The Performance Security amount is 03% (Three Percent) of Contract Price.	Performance Security amount mentioned as per SBD terms and conditios.
3	BOQ 1	Item No.22	Power transformer 33 KV VCB with static Tri-vector energy meter specification not provided in the SBD kindly arrange the same.	Static Tri-vector meter to be installed in Power Transformer Control & Relay panel (Cl: 0.2S, Ib: 1A, Imax: 2A, 3 ph, 4 wire, -/110V/V3, -/1A, 50Hz)
4	BOQ 1	ltem no.33	11 KV LA station class Rating not mentioned in the BOQ	Item No. 24 : Read as 27kV MCOV instead of 9kV Item No. 33 : 9kV MCOV
5	BOQ 1	ltem no.35	3 Mtr Channel with clamp Dimensions are not mentioned for channel and clamp in the BOQ	Channel Dimension -75x40x6mm
6	BOQ 1	ltem no.37	As per BOQ it is mentioned that Stay set complete. Please clarify whether it is 11 KV Stay set or 33 KV Stay set.	11kV
7	BOQ 1	ltem No. 38	As per BOQ it is mentioned that 3Cx3OO sq mm UG cable please clarify whether it <i>is</i> 11 KV or 33 KV.	11kV
8	BOQ 1	ltem No. 39	As per BOQ it is mentioned that 1CX500 sq mm UG cable please clarify whether it is 11 KV or 33 KV.	11kV
9	BOQ 1	ltem No. 47	As per BOQ it is mentioned that MS Rod 25 mm please specify the length, CLASS and Drawing of the MS Rod.	MS Rod 25mm - Threaded Type, 1mtr. Length
10	BOQ 1	ltem No. 48, 53, 69, & 81	As per BOQ it is mentioned that Miscellaneous please specify the items which will comes under Miscellaneous so that we can quote our price.	Any missed or additional items to be included in miscellaneous (e.g. Bolt, Nuts, clampsetc.)
11	BOQ 1	ltem No. 60- 64	As per BOQ It is mentioned that Suitable glands and Lugs in one item please provide the breakup for gland and lugs separately so that we can quote the price accordingly.	Item No. 60 to 64 ; Varoius types of 520 Nos. glands and 1600 Nos. lugs, based on different cable sizes.
12	BOQ 1	ltem No. 80	LT Distribution Boards for 100 kVA to 500 KVA Please provide the breakup details rating wise and arrange drawings and technical specifications.	Suitable size Distribution Box size is required, front opening door, will fixed in DTR seconday side. It shall be provided with 630A busbars (r,y,b,n) and 2 sections HRC Type fuses.

Thrissur Corporation Electricity Department (TCED), Thrissur- 680001, Kerala-State