Date: 27-8-2025

Notice Inviting Tender / e-Tender / Quotation

Thrissur Corporation Electricity Department invites sealed quotation / open tenders / e-Tenders from eligible applicants, who fulfill the qualification criteria as stipulated in the Store Purchase Manual Kerala, Kerala PWD Code & LGSD Tender regulations for the Supply / Work mentioned in the below-tabulation sheet.

The details of the Tender are as per following:

Approximate Cost of Supply / Work	:	497600/-		
Supply / Work Description	:	Supply of HRC Fuses		
Tender Security / EMD / Amt.	:	5000/-		
Cost of Tender Form	:	1000 + 120		
Tender Document on Sale	:			
A.S. approved by	:	Q# 70 ptd 29/7/25		
T.S approved by	:			
Last Date & Time of issuing Tender Form		26.9.2025 . 12 pm		
Last Date & Time of Submitting Tender	:	26-9-2025 1 pm		
Date & Time of Opening Tender	:	26.9-2025 3 pm.		
Authority & Place for submit of Tender	:	Electricity Department, Thrissur Corporation – 680001		

^{*} Sale of Tender form available only after 2. P.M. everyday once tender floated.

* Those who participate in work tender should own concerned electrical contract licensee.

Assistant Secretar

N K KRISHNAKUMAR
ASSISTANT SECRETARY
ELECTRICITY DEPARTMENT
THRISSUR MUNICIPAL CORPORATION
PEN - 743648

PH No: 8921937758

^{*} Applicants must have GST Registration

^{*} Quoted rate should be inclusive of relevant Taxes

^{*} Tender inviting officer shall have every right to revoke tender / quotation at any time without any reason

HRC fuses purchase

o	M	ω	N		Slno
HRC Fuse Base 400A	HRC Fuse Base 250 A	HRC Fuse Link 400A	HRC Fuse Link 315A	HRC Fuse Link 250A	ltem
HRC Fuse Base made with body of high grade flame retardant non- hygroscopic phenolic moulding with a hard gloss surface in off white / balck finish having high electrical properties with high tracking resistance and Contact material made up of ETP grade copper which is silver plated for ensuring low temperature rise, conforming to IEC 60269 / IS 13703 with IEC standard size of 02 for the Rated current 400A & Rated voltage 500v AC	HRC Fuse Base made with body of high grade flame retardant non- hygroscopic phenolic moulding with a hard gloss surface in off white / balck finish having high electrical properties with high tracking resistance and Contact material made up of ETP grade copper which is silver plated for ensuring low temperature rise, conforming to IEC 60269 / IS 13703 with IEC standard size of 01 for the Rated current 250A & Rated voltage 500v AC	HRC fuse link of rating 400A Made up of ETP gade copper with silver plating conforming to IEC 60269 / IS 13703 / BS 88 with IEC standard of size 2 .Rated Voltage at 415 - 500v AC with high breaking capacity upto 80KA at 415/500v AC.	HRC fuse link of rating 315A Made up of ETP gade copper with silver plating conforming to IEC 60269 / IS 13703 / BS 88 with IEC standard of size 2 .Rated Voltage at 415 - 500v AC with high breaking capacity upto 80KA at 415/500v AC.	HRC fuse link of rating 250A Made up of ETP gade copper with silver plating conforming to IEC 60269 / IS 13703 / BS 88 with IEC standard of size 2 .Rated Voltage at 415 - 500v AC with high breaking capacity upto 80KA at 415/500v AC.	Specification
NOs	NOs	SON	NOS	NOs	Unit
130	60	3	100	60	qty rqd

TOTAL