

File No.: ESS - 2806/23

Date: 01/01/2024


Notice Inviting Tender / e-Tender / Quotation

Thrissur Corporation Electricity Department invites sealed quotation / open tenders / e-Tenders from eligible applicants, who fulfill the qualification criteria as stipulated in the Store Purchase Manual Kerala, Kerala PWD Code & LGSD Tender regulations for the Supply / Work mentioned in the below-tabulation sheet.

The details of the Tender are as per following :

Approximate Cost of Supply / Work	:	107380/- (Including Gst)
Supply / Work Description	:	Supply of 33 KV Transformer oil filled current transformer with metallic enclosure and bushings suitable for outdoor applications as per IEC 61869-2, IS 16227 Part 2 (Nov)
Tender Security / EMD / Amt.	:	Rs 1100/-
Cost of Tender Form	:	Rs 400 + 48 (gst)
Tender Document on Sale	:	
A.S. approved by	:	Resolution no 105 dt 4/10/23 of Hon'ble corporation council
T.S approved by	:	Electrical Engineer, TCD
Last Date & Time of issuing Tender Form	:	20/01/24 12:30 pm
Last Date & Time of Submitting Tender	:	20/01/24 2:30 pm
Date & Time of Opening Tender	:	20/01/24 4 pm
Authority & Place for submit of Tender	:	Electricity Department, Thrissur Corporation - 680001

- * Sale of Tender form available only after 2. P.M. everyday once tender floated.
- * Applicants must have GST Registration
- * Quoted rate should be inclusive of relevant Taxes
- * Tender inviting officer shall have every right to revoke tender / quotation at any time without any reason
- * Those who participate in work tender should own concerned electrical contract licensee.


 Assistant Secretary

എസ്. കെ. കൃഷ്ണകുമാർ S. KRISHNAKUMAR M.A., LL.M.
 അസിസ്റ്റന്റ് സെക്രട്ടറി/ASSISTANT SECRETARY
 വൈദ്യുതി വിഭാഗം/ELECTRICITY DEPARTMENT
 തൃശ്ശൂർ കോർപ്പറേഷൻ/THRISSUR CORPORATION
 ഫോൺ നമ്പർ/Pen No: 743548
 ഫോൺ/Phone - 8487 2422470
 മൊബൈൽ/Mobile - 8921037758

For tender purpose:

Supply of the followings

No	Description	Core	Ratio	Rated Burden(VA)	Class
1	2 Nos of 33kV Tranformer Oil filled Current transformer with metallic enclosure and bushings suitable for outdoor application as per IEC61869-2 , IS 16227 Part-2	1	400-200-100/1A	30VA	5P10
		2	400-200-100/1A	10VA	.2S
		3	400-200-100/1A	Kn _p V ≥300V at ≤50mA; R _{ct} ≤ 4Ω@75°C	PS
		4	400-200-100/1A	Kn _p V ≥300V at ≤50mA; R _{ct} ≤ 4Ω@75°C	PS

(Signature)