

File No.: Ess - 2961 / 23

Date : 06.02.2024

Notice Inviting Tender / e-Tender / Quotation

Thrissur Corporation Electricity Department invites sealed quotation / open tenders / e-Tenders from eligible applicants, who fulfill the qualification criteria as stipulated in the Store Purchase Manual Kerala, Kerala PWD Code & LGSD Tender regulations for the Supply / Work mentioned in the below-tabulation sheet.

The details of the Tender are as per following :

Approximate Cost of Supply / Work	:	<u>Rs 3,19,190/- (Including Gst)</u>
Supply / Work Description	:	<u>Supply of 12kv, 25kv, 1250A Metal clad VCB trolley with PT for Megawin make indoor panel 11kv as per tender Specifications.</u>
Tender Security / EMD / Amt.	:	<u>Rs 3200/-</u>
Cost of Tender Form	:	<u>700 + 84 (gst) = 784/-</u>
Tender Document on Sale	:	
A.S. approved by	:	<u>Resolution No.27 dt 10/11/2024</u>
T.S. approved by	:	<u>By electrical Engineer, TCGD</u>
Last Date & Time of issuing Tender Form	:	<u>27-02-2024 1pm</u>
Last Date & Time of Submitting Tender	:	<u>27.02.2024 3pm</u>
Date & Time of Opening Tender	:	<u>27.02.2024 4pm</u>
Authority & Place for submit of Tender	:	<u>Electricity Department, Thrissur Corporation - 680001</u>

- * Sale of Tender form available only after 2. P.M. everyday once tender floated.
- * Applicants must have GST Registration
- * Quoted rate should be inclusive of relevant Taxes
- * Tender inviting officer shall have every right to revoke tender / quotation at any time without any reason
- * Those who participate in work tender should own concerned electrical contract licensee.


 Assistant Secretary
 എൻ. കെ. കൃഷ്ണകുമാർ N. K. KRISHNAKUMAR M.A., LL.
 അസിസ്റ്റന്റ് സെക്രട്ടറി ASSISTANT SECRETARY
 വൈദ്യുതി വിഭാഗം/ELECTRICITY DEPARTMENT
 തൃശ്ശൂർ നഗരസഭ/THRISSUR CORPORATION
 ഫോൺ നമ്പർ/Phone No: 743648
 ഫോൺ നമ്പർ/Phone - 0487 2422470
 മൊബൈൽ/ Mobile - 8921037758
 ഇമെയിൽ/Email : electricitydepartment@yahoo.c

SPECIFICATIONS

MAKE	MEGAWIN
TYPE	MHVCB
RATED VOLTAGE	12 KV
RATED CURRENT	1250 A
RATED FREQUENCY	50 HZ
RATED SHORT CIRCUIT BREAKING CURRENT	26.2 KA
RATED SHORT CIRCUIT DURATION	1 SEC
INSULATION LEVEL	12/28/75
OPERATING SEQUENCE	0-3 MIN – 3 MIN CO
SHUNT TRIP VOLTAGE	110 V DC
MOTOR VOLTAGE	230 V AC
MEASUREMENTS	(114*49) CM <small>114 cm → Height 49 cm → Width.</small>
POTENTIAL TRANSFORMER	3Φ, CL- 0.2 S , 100 VA, DRAW OUT TYPE



JOSE T.S
Electrical Engineer
Electricity Department
Tribal Corporation
1st. 2003